

Attestation

WELL Building Standard™

On the 2nd of April 2025 Eurofins Product Testing A/S received a sample of a water-based coating with the product name:

FirePro FlexSeal Coating

supplied by

Rockwool Ltd.

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the AgBB (2024)/EN 16516 (2017) with EU LCI VOC threshold values and ISO 11890-2 (2020) test standards (See test report no. 392-2025-00181002_A_EN and 392-2025-00181007_XG_EN).

The tested product complies with the requirements of WELL v2 Feature X06 VOC Restrictions: Part 1 by complying with:

VOC emissions specifications:

- The requirements of AgBB (2024).

VOC content specifications:

- The requirement of the EU Decopaint Directive 2004/42/CE for 'One-pack performance coating, WB' having a VOC content below 140 g/L.

16 July 2025



Claus Bonde
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager

The International WELL Building Institute (IWBI) is a public benefit corporation whose mission is to improve human health and well-being in buildings and communities across the world through its WELL Building Standard (WELL). WELL™ and the related logo are trademarks owned by the IWBI and are used with permission.