

# Attestation

## AgBB

On the 2<sup>nd</sup> of April 2025 Eurofins Product Testing A/S received a sample of a water-based coating with the product name:

### FirePro FlexSeal Coating

supplied by

### Rockwool Ltd.

The emissions were tested according to AgBB (AgBB - Committee for Health-related Evaluation of Building Products). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 testing standards (see the test report no.392-2025-00181002\_A\_EN).

#### **Evaluation of the emission test result according to AgBB:**

- The sum of VOC ("TVOC") after 3 days was in compliance with the limit of  $\leq 10$  mg/m<sup>3</sup>.
- The sum of VOC ("TVOC") after 28 days was in compliance with the limit of  $\leq 1$  mg/m<sup>3</sup>.
- The sum of SVOC after 28 days was in compliance with the limit of  $\leq 0.1$  mg/m<sup>3</sup>.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5  $\mu$ g/m<sup>3</sup>. This value R was in compliance with the limit of  $\leq 1$ .
- The sum of VOC without LCI-value after 28 days was in compliance with the limit of  $\leq 0.1$  mg/m<sup>3</sup>.
- The concentration of formaldehyde after 28 days was in compliance with the limit of  $\leq 0.1$  mg/m<sup>3</sup>.
- Carcinogenic substances were not detectable after 3 and after 28 days

**The tested product complies with the requirements of AgBB including the NIK-values (September 2024) for use in the indoor environment.**

16 July 2025



Claus Bonde  
Analytical Service Manager



Rasmus Verdier  
Analytical Service Manager